



IEAGHG 8th Post Combustion Capture Conference

16th to 18th September 2025 Marseille, France

Electrochemical CO₂ Capture: Demonstration of new technology at industrial sites across Europe

Sai Hema Bhavya Vinjarapu^{a*}, Sara Vallejo Castano^b, Randi Neerup^a, Magor Demeter^a, Istvan Gyorbiro^a, Rasmus Engilbertsson^a, Nikki Dommer^a, Andreas Bandier^a, Pantelis Bountzis^a, Nomiki Kottaki^a, Elham Ramin^a, Sebastian Villadsen^a, Philip Fosbøl^a

^aCenter for Energy Resources Engineering (CERE), Technical University of Denmark, Søtofts Plads, 2800 Kgs Lyngby, Denmark

^bWetsus, European Centre of Excellence for Sustainable Water Technology, Oostergoweg 9, Leeuwarden 8911 MA, Netherlands

Keywords: Novel technology; PtX; Inorganic solvent; Demonstration scale; Electrochemistry

Introduction

Post-combustion CO₂ capture (PCCC) is a vital technology for reducing carbon emissions. The most commonly adapted technology is amine-based solvent capture. However, this method presents challenges such as high energy consumption, solvent degradation, corrosion, and emissions. In contrast, inorganic solvents like potassium hydroxide (KOH) remain underexplored for PCCC. Since KOH does not react with oxygen, it eliminates the issue of oxidative degradation—a major concern in amine-based systems. Additionally, electrochemical regeneration of KOH has demonstrated energy consumption levels comparable to amine-based methods (Shi et al., 2024; Vallejo Castaño et al., 2024).

This study presents a pilot-scale demonstration of CO₂ capture using a KOH-based solvent, coupled with electrochemical regeneration. The pilot demonstrations were conducted at two industrial sites: OMV Petrom in Romania and Grecian Magnesite in Greece.

Demonstration Unit

The demonstration unit comprises three main modules: capture, regeneration, and utilization. It has a CO₂ capture capacity of 100 kg/h.

- **Capture Module:** This module includes a pre-scrubber, an absorber, and a wash column. The pre-scrubber conditions the flue gas by removing SO_x and NO_x before it enters the absorber. Inside the absorber, the gas interacts with a 1 molal KOH solution, forming potassium carbonate (K₂CO₃) and potassium bicarbonate (KHCO₃). The CO₂-rich solvent is then directed to the regeneration module (see Figure 2).

- **Regeneration Module:** This module consists of two electrochemical stacks, each containing 126 cell pairs. It is a scaled-up version of a lab setup, details of which are available in a previous publication (Shi et al., 2024; Vallejo Castaño et al., 2024).
- **Process Overview:** A simplified process flow diagram of the absorption column and the electrochemical stack is shown in Figure 1.

This pilot-scale demonstration highlights the potential of KOH as an alternative solvent for PCCC, offering a promising route for more efficient and sustainable carbon capture.




Figure 1: Simplified process flow diagram of the capture and electrochemical regeneration of CO₂

Demonstration sites

The demonstration of this novel technology took place at three industrial sites under varying flue gas conditions. It was tested at the Aalborg Portland cement facility in Denmark from December 2023 to May 2024, at the OMV Petrom refinery in Romania from June 2024 to November 2024, and at Grecian Magnesite from January 2025 to June 2025. Each site presented distinct CO₂ concentrations, saturation temperatures, and impurity levels, including SO_x and NO_x. These variations ensured the technology's robustness and provided valuable insights into stack design, enhancing overall system performance and adaptability.



Figure 2: Demonstration unit at Aalborg Portland (left) and Grecian Magnesite (right)

Table 1 provides the composition of the flue gas at the three different locations highlighting the variability of the concentration of CO₂ and impurities present.

Table 1: Composition of flue gas at the three test sites

Parameter	Aalborg Portland	OMVPET	Grecian Magnesite
Temperature (°C)	122	170	150-200
CO ₂ (vol%)	20.9	3.5	15
O ₂ (vol%)	6.9	14.5	7-15
H ₂ O (vol%)	35	6.5	6-13
SO ₂ (mg/Nm ³)	0.29	22	1500
NO _x (mg/Nm ³)	253	95	700-1500
Particles/dust (mg/Nm ³)	11.2	1.7	-

Experimental Campaigns and Results

Experimental campaigns were designed to assess the pilot's performance under varying operating conditions, including current density, load ratio, L/G values, and CO₂ concentration. These tests have provided critical insights into the system's efficiency and ensured its reliability across different ambient and flue gas conditions.

Since this technology has rarely been demonstrated at scale, its pilot implementation across multiple industrial sites has offered valuable knowledge about its performance and potential challenges for full-scale deployment.

Acknowledgements

This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement N°101022484

References

- Shi, M., Castaño, S. V., Shu, Q., Tedesco, M., Kuntke, P., Hamelers, H. V., & Fosbøl, P. L. (2024). Carbon capture via electrochemically mediated alkaline absorption: Lab-scale continuous operation. *Journal of Cleaner Production*, 476, 143767
- Castaño, S. V., Shu, Q., Shi, M., Blauw, R., Fosbøl, P. L., Kuntke, P., ... & Hamelers, H. V. (2024). Optimizing alkaline solvent regeneration through bipolar membrane electrodialysis for carbon capture. *Chemical Engineering Journal*, 488, 150870.