



**OGT** | ProTreat®



# Simultaneous CAPEX and OPEX optimization of a carbon capture plant


## Combined-Cycle Gas Turbine case study

Debadrita Ganguly, Diego Di Domenico Pinto, Hovyu

Prashanth Chandran, Simon Weiland, OGT

17.09.2025

# Carbon capture process




*Flowsheet of Carbon capture process*

- Conventional amine-based process
- Energy requirements for reboiler – solvent type, flue gas composition & process operating conditions.
- Typically, 2.5 to 3.6 MJ/kgCO<sub>2</sub>
- CESAR1 less energy intensive than MEA
- CESAR1 reaction slower compared to MEA

# Cost analysis for carbon capture plant




- First energy optimization, then estimation of cost for few selected cases.
- ProTreat® version 9.0 – New case study feature, run multiple configurations. New thermodynamic model for CESAR1 – avg. capture rates < 2% deviation<sup>1</sup>.
- New cost estimation tool developed – simultaneous optimization of CAPEX & OPEX





# Combined Cycle Gas Turbine process




| Without Carbon Capture |    |        |
|------------------------|----|--------|
| Air compressor         | MW | 244.9  |
| LP pump                | kW | 71.4   |
| IP pump                | kW | 32.7   |
| HP pump                | kW | 1311.0 |
| Gas turbine            | MW | 507.5  |
| LPST                   | MW | 66.3   |
| IPST                   | MW | 46.6   |
| HPST                   | MW | 29.0   |
| Net power output       | MW | 403.0  |

Z. Liu and I. A. Karimi, “Simulating combined cycle gas turbine power plants in Aspen HYSYS,” Elsevier, Jun. 2018.

# CCGT Power plant with carbon capture



PCCC-8



- Capture plant with CCGT plant modelled in ProTreat®
- Steam extracted from LPST
- Electricity required for pumps & blowers of capture process

# Capital Cost Estimate

- Methodology for cost estimation described in [1].
- Class 4 type study – accuracy range between -10% to -20% (low side) to +20% to +30% (high side).
- Costs updated to current values using Chemical Engineering Plant Cost Index (CEPCI)


## Assumptions for equipment cost calculation

| Equipment                 | Type                                                                                    |
|---------------------------|-----------------------------------------------------------------------------------------|
| Pumps                     | Centrifugal                                                                             |
| Heat Exchangers           | Flat plate                                                                              |
| Columns (Process vessels) | Vertical                                                                                |
| Vessels                   | Vertical                                                                                |
| Column specifications     |                                                                                         |
| DCC                       | Includes demister                                                                       |
| Absorber                  | Includes demister, dry bed packing, Water wash and Acid wash section stacked at the top |
| Stripper                  | Includes dry bed packing                                                                |

[1] R. Turton, J. A. Shaeiwitz, D. Bhattacharyya, and W. B. Whiting, *Analysis, Synthesis, and Design of chemical processes*, vol. Fifth Edition. 2018.


# Cost estimation of equipment

Module costing Technique used for estimating bare module cost of equipment.



- Purchased cost of base equipment – carbon steel and ambient pressure operations
- Bare module : correction factors , installation costs

# Total CAPEX estimation




# Estimation of OPEX

## Variable OPEX

|                                            | Price | Unit    |
|--------------------------------------------|-------|---------|
| Electricity                                | 64    | EUR/MWh |
| Cooling Water                              | 0.02  | EUR/ton |
| Process Water                              | 0.177 | EUR/ton |
| Cost of AMP                                | 8000  | EUR/ton |
| Cost of Piperazine                         | 8000  | EUR/ton |
| Cost of MEA                                | 2000  | EUR/ton |
| NaOH (DCC)                                 | 850   | EUR/ton |
| H <sub>2</sub> SO <sub>4</sub> (acid wash) | 1500  | EUR/ton |
| Chemical Handling                          | 500   | EUR/ton |

# Estimation of Fixed OPEX






# Cost parameters to compare cases


- Operation hours – 8000 hours in a year
- Annualized CAPEX (€/year) :  
Project lifetime – 25 years  
Discount rate (to account for time value of money) – 6%
- OPEX ( summation of Fixed and Variable) [€/year]
- Total cost in [€/year] : Annualized CAPEX + OPEX
- Revenue loss : Loss in power output due to capture process taken in consideration

## MEA Case study




- Case study : input parameter varied – solvent flowrate
- Two cases : Absorber packing height 10m & 15 m with IC @ 4m
- DCC packing – 4m, Stripper packing – 20m
- Capture rate : 95%
- SRD optimum for 10m ; 5.77 MJ/ kgCO<sub>2</sub>
- SRD optimum for 15m ; 3.71 MJ/ kgCO<sub>2</sub>

# CESAR1 case study




- Case study : input parameter varied – solvent flowrate
- Two cases : Absorber packing height 20m & 26 m with IC @ 4m
- DCC packing – 4m, Stripper packing – 20m
- Capture rate : 95%
- SRD optimum for 20m ; 3.47 MJ/ kgCO<sub>2</sub>
- SRD optimum for 26m ; 3.05 MJ/ kgCO<sub>2</sub>


## MEA case – Abs 10m IC 4m case



## MEA case – Abs 15m IC 4m case




# CESAR1 case – Abs 20m IC 4m case






# CESAR1 case – Abs 26m IC 4m case




# Comparison of Total cost for MEA cases



SRD lower for 15m Absorber packing height :  
**3.71 MJ/ kgCO<sub>2</sub>**  
Total cost higher : **102.4 M€/y**

SRD higher for 10m Absorber packing height :  
**5.77 MJ/ kgCO<sub>2</sub>**  
Total cost lower : **113.3 M€/y**

# Comparison of Total cost for CESAR1 cases



SRD lower for 26m Absorber packing height :  
**3.05 MJ/ kgCO<sub>2</sub>**  
Total cost higher : **121.0 M€/y**

SRD higher for 20m Absorber packing height :  
**3.47 MJ/ kgCO<sub>2</sub>**  
Total cost lower : **116.3 M€/y**

## Conclusion

- Minimum reboiler duty results in lowering variable OPEX but not the total cost of capture plant.
- Taller columns contribute to larger CAPEX, which increases Fixed OPEX and the resulting Total Cost.
- Cost of the capture plant depends on configurations – taller columns, with/without Inter-coolers.
- For a given configuration, capture plant costs remain relatively stable for most of the points on SRD curve, rising noticeably only at the extremes where SRD increases sharply.
- ProTreat v9 case study feature allows for simulating multiple points (approx.30-40) in 10-15 minutes. All the necessary output variables can be generated, allows for calculating cost of each point on SRD curve. Reduces the time taken to evaluate cost of capture process for multiple configurations.

## Upcoming tasks

- Explore different configurations, vary Stripper height, compare setups with and without Inter-coolers using this method.



**PCCC-8**

# Thank You



# BACKUP slides



# Cash flow analysis

ETS price : 85€/t  
Discount rate : 10%  
Electricity selling price : 64 €/MWh

